


PMC-EF2a
(20102)

**U.S. DEPARTMENT OF ENERGY
EERE PROJECT MANAGEMENT CENTER
NEPA DETERMINATION**



RECIPIENT: Nevada State Office of Energy STATE: NV

PROJECT TITLE : Alternative Fuel Fueling Infrastructure

Funding Opportunity Announcement Number	Procurement Instrument Number	NEPA Control Number	CID Number
DE-FOA-0000052	EE0000084	GFO-10-145	0

Based on my review of the information concerning the proposed action, as NEPA Compliance Officer (authorized under DOE Order 451.1A), I have made the following determination:

CX, EA, EIS APPENDIX AND NUMBER:

Description:

B2.5 Safety and environmental improvements of a facility, including replacement and upgrade of facility components, that do not result in a significant change in the expected useful life, design capacity, or function of the facility and during which operations may be suspended and then resumed. Improvements may include, but are not limited to:
 Replacement/upgrade of control valves, in-core monitoring devices, facility air filtration systems, or substation transformers or capacitors; addition of structural bracing to meet earthquake standards and/or sustain high wind loading; and replacement of aboveground or belowground tanks and related piping if there is no evidence of leakage based on testing that meets performance requirements in 40 CFR part 280, subpart D (40 CFR part 280.40). This includes activities taken under RCRA, subtitle I; 40 CFR part 265, subpart J; 40 CFR part 280, subparts B, C, and D; and other applicable state, Federal and local requirements for underground storage tanks. These actions do not include rebuilding or modifying substantial portions of a facility, such as replacing a reactor vessel.

Rational for determination:

The funding for Nevada's SEP Grant for their "Alternative Fuel Fueling Infrastructure", will be applied to the total project of installing a double walled multi-product above ground fuel tank. The project will replace a 2000 gallon fireguard regular unleaded gasoline above ground fuel tank with a double walled above ground multi-product tank with a capacity of 1500-2000 gallons of regular unleaded fuel and 1500-2000 gallons of E-85. The new tank will replace the old tank and use the same supports and system. The tank that is removed will be used at another facility by the fuel provider.

In the performance of work in all program areas, grantees will be required to comply with all applicable federal, state and local laws, regulations and standards, including but not limited to the handling, storage, transportation and disposal of waste. If a grantee proposes work that may affect an historic property or archaeological resource listed in or determined to be eligible for the National Register of Historic Places, the grantee will be required to comply with the requirements of Section 106 of the National Historic Preservation Act.

This project comprises of upgrading components of an existing facility; therefore they are CX'd under B2.5.

NEPA PROVISION

DOE has made a final NEPA determination for this award

Insert the following language in the award:

Note to Specialist :

None Given.

SIGNATURE OF THIS MEMORANDUM CONSTITUTES A RECORD OF THIS DECISION.

NEPA Compliance Officer Signature: 
 NEPA Compliance Officer

Date: Feb/9/10

FIELD OFFICE MANAGER DETERMINATION

Field Office Manager review required

NCO REQUESTS THE FIELD OFFICE MANAGER REVIEW FOR THE FOLLOWING REASON:

- Proposed action fits within a categorical exclusion but involves a high profile or controversial issue that warrants Field Office Manager's attention.
- Proposed action falls within an EA or EIS category and therefore requires Field Office Manager's review and determination.

BASED ON MY REVIEW I CONCUR WITH THE DETERMINATION OF THE NCO :

Field Office Manager's Signature: _____ Date: _____
 Field Office Manager

(Faint, mostly illegible text from the reverse side of the page, including phrases like "The finding for Nevada's BEP Grant for the 'Alternative Fuel Fueling Infrastructure' will be applied to the total project of installing a double-walled multi-product above ground fuel tank...")

RECITATION OF THIS MEMORANDUM TO ESTABLISH A RECORD OF THIS DECISION
 NEPA Compliance Officer Signature: _____
 Date: Feb 19/10