

PMC-EF2a

(2/04/02)

**U.S. DEPARTMENT OF ENERGY
EERE PROJECT MANAGEMENT CENTER
NEPA DETERMINATION**



RECIPIENT:Oklahoma Municipal Power Authority

STATE: OK

PROJECT TITLE : OKLAHOMA SEP ARRA - OMPA Large Systems Request AE

Funding Opportunity Announcement Number	Procurement Instrument Number	NEPA Control Number	CID Number
DE-FOA-0000052	DE-EE0000133	GFO-0000133-058	0

Based on my review of the information concerning the proposed action, as NEPA Compliance Officer (authorized under DOE Order 451.1A), I have made the following determination:

CX, EA, EIS APPENDIX AND NUMBER:

Description:

B5.19 Ground source heat pumps

The installation, modification, operation, and removal of commercially available smallscale ground source heat pumps to support operations in single facilities (such as a school or community center) or contiguous facilities (such as an office complex) (1) only where (a) major associated activities (such as drilling and discharge) are regulated, and (b) appropriate leakage and contaminant control measures would be in place (including for cross-contamination between aquifers); (2) that would not have the potential to cause significant changes in subsurface temperature; and (3) would be located within a previously disturbed or developed area. Covered actions would be in accordance with applicable requirements (such as local land use and zoning requirements) in the proposed project area and would incorporate appropriate control technologies and best management practices.

Rational for determination:

DOE is proposing to provide \$7,650 in SEP funding to the Oklahoma Department of Commerce, who is proposing to fund the Oklahoma Comfort Program through their sub-grantee the Oklahoma Municipal Power Authority (OMPA).

The following NEPA review is for the replacement of existing heat pumps for a vertical, ground source heat pump (GSHP) at the Heiman home (4301 Rock Canyon Rd, Edmond OK 73025). The total tonnage of the system is 7.65 tons.

The state certified and licensed driller would follow IGSHA and NGWA regulations during installation. The system would use HDPE piping that is heat fused and all wells would be fully grouted with a thermally enhanced bentonite grout. Only potable water would be used in the proposed system. All loops would be pressure tested before and after installation. Minimal land disturbance of less than 5,000 square feet would occur at the project site.

The Heiman home is located two miles northwest of Edmond, Oklahoma. The proposed project would replace the existing heat pumps, which were originally installed in 1980. The existing GSHP has one, 4.55-ton unit and one, 3.10-ton unit. Loops made of HDPE pipes would be inserted into the boreholes. Manifolds would connect the loops to the heat pumps.

The existing GSHP system is a once through system as opposed to a closed loop system. The Central Oklahoma aquifer is the source. According to the USGS, this aquifer underlies approximately 3,000 square miles of central Oklahoma and is used for municipal, industrial, commercial, agricultural and domestic water supplies. The system uses 3 gallons per minute (gpm) per ton. No refrigerants or other chemicals are used, only water. After passing through the system, the water is discharged into Coffee Creek on the Heiman property, which eventually feeds into Lake Arcadia.

The formation underlying the property is 3 to 5 feet of clay above layers of sandstone. Areas containing karst topography and related federally listed species in Oklahoma have been identified, and the proposed project would not occur in proximity to those resources. Based on this information, DOE has determined the proposed GSHP project would not have adverse impacts on these resources.

As required by the OK SEO, installation of ground source heat pumps cannot commence at any proposed OCP installation site until State Historical Preservation Office (SHPO) approval has been received. OMPA must submit information about all prospective GHP installation sites to the Oklahoma State Energy Office (SEO) for review by SHPO. Under a Programmatic Agreement with SHPO, OK SEO can approve sites with buildings that are less than 45 years old. For buildings 45 years old or older, SEO must submit details to SHPO for review.

Based on this information, DOE has determined the work outlined is consistent with activities identified in categorical exclusion B5.19 (installation of ground source heat pumps).

NEPA PROVISION

DOE has made a final NEPA determination for this award


Insert the following language in the award:

If you intend to make changes to the scope or objective of your project you are required to contact the Project Officer identified in Block 11 of the Notice of Financial Assistance Award before proceeding. You must receive notification of approval from the DOE Contracting Officer prior to commencing with work beyond that currently approved.

Note to Specialist :

Cristina Tyler 2.1.2012

SIGNATURE OF THIS MEMORANDUM CONSTITUTES A RECORD OF THIS DECISION.

NEPA Compliance Officer Signature:  Date: 2/10/2012
NEPA Compliance Officer

FIELD OFFICE MANAGER DETERMINATION

Field Office Manager review required

NCO REQUESTS THE FIELD OFFICE MANAGER REVIEW FOR THE FOLLOWING REASON:

- Proposed action fits within a categorical exclusion but involves a high profile or controversial issue that warrants Field Office Manager's attention.
- Proposed action falls within an EA or EIS category and therefore requires Field Office Manager's review and determination.

BASED ON MY REVIEW I CONCUR WITH THE DETERMINATION OF THE NCO :

Field Office Manager's Signature: _____ Date: _____
Field Office Manager