

PMC-EF2a

(2.04.02)

**U.S. DEPARTMENT OF ENERGY
EERE PROJECT MANAGEMENT CENTER
NEPA DETERMINATION**



RECIPIENT: Oklahoma Municipal Power Authority

STATE: OK

PROJECT TITLE : OKLAHOMA SEP ARRA - OMPA Large Systems Request AI

Funding Opportunity Announcement Number	Procurement Instrument Number	NEPA Control Number	CID Number
DE-FOA-0000052	DE-EE0000133	GFO-000133-062	

Based on my review of the information concerning the proposed action, as NEPA Compliance Officer (authorized under DOE Order 451.1A), I have made the following determination:

CX, EA, EIS APPENDIX AND NUMBER:

Description:

B5.19 Ground source heat pumps The installation, modification, operation, and removal of commercially available smallscale ground source heat pumps to support operations in single facilities (such as a school or community center) or contiguous facilities (such as an office complex) (1) only where (a) major associated activities (such as drilling and discharge) are regulated, and (b) appropriate leakage and contaminant control measures would be in place (including for cross-contamination between aquifers); (2) that would not have the potential to cause significant changes in subsurface temperature; and (3) would be located within a previously disturbed or developed area. Covered actions would be in accordance with applicable requirements (such as local land use and zoning requirements) in the proposed project area and would incorporate appropriate control technologies and best management practices.

Rational for determination:

DOE is proposing to provide \$12,880 in SEP funding to the Oklahoma Department of Commerce, who is proposing to fund the Oklahoma Comfort Program through their sub-grantee the Oklahoma Municipal Power Authority (OMPA).

The proposed project is a vertical, closed-loop ground source heat pump (GSHP) that would be installed at the Steppe home (3121 South Air Depot Boulevard, Edmond, Oklahoma 73013). A total of 12.88 tons would be installed in the backyard of the Steppe residence.

The state certified and licensed driller would follow IGSHPA and NGWA regulations during installation. The system would use HDPE piping that is heat fused and all wells would be fully grouted with bentonite. The refrigerant used in the system would be a non-toxic, food grade 15% propylene glycol and water mixture. All loops would be pressure tested before and after installation. Land disturbance of less than 2,500 square feet would occur at the proposed site. All sod removed during drilling would be replaced.

The Steppe home is located 3.5 miles southeast of Edmond, Oklahoma and 0.4 miles west of Arcadia Lake. There are two, 0.5 acre non-navigable stock ponds 350 yards from the home. The home is located in a lightly populated neighborhood. Each residence is at least 500 feet apart.

The proposed system would consist of two, 4.34-ton units and two, 2.1-ton units served by a common loop consisting of twelve boreholes. Each borehole would be situated at least ten feet apart, be six-inches in diameter and 250 feet deep. Loops made of HDPE pipes would be inserted into the boreholes. Manifolds would connect the loops to the heat pumps. Approximately two yards of uncontaminated sandstone spoils would be created during the drilling of the boreholes. The spoils would be properly disposed of at a sanitary landfill.

The proposed systems would not impact groundwater. There are no aquifers within 200 feet of the surface. If a system were to reach an aquifer, the aquifer would be protected because the system would be installed using techniques that protect the groundwater and the loop fluids from contaminating one another. The formation underlying both properties is 3 to 5 feet of clay above layers of sandstone.

Areas containing karst topography and related federally listed species in Oklahoma have been identified, and the proposed projects would not occur in proximity to those resources. Based on this, DOE has determined there would be no adverse impacts to these resources as a result of the proposed GSHP project.

As required by the OK SEO, installation of ground source heat pumps cannot commence at any proposed OCP installation site until State Historical Preservation Office (SHPO) approval has been received. OMPA has submitted

information for the proposed GSHP installation sites to the Oklahoma State Energy Office (SEO) for review by SHPO. Under a Programmatic Agreement with SHPO, OK SEO can approve sites with buildings that are less than 45 years old. For buildings 45 years old or older, SEO must submit details to SHPO for review.

Based on this information, DOE has determined the work outlined is consistent with activities identified in categorical exclusion B5.19 (installation of ground source heat pump).

NEPA PROVISION

DOE has made a final NEPA determination for this award

Insert the following language in the award:

Note to Specialist :

Cristina Tyler 6.4.2012

SIGNATURE OF THIS MEMORANDUM CONSTITUTES A RECORD OF THIS DECISION.

NEPA Compliance Officer Signature:

[Handwritten Signature]
NEPA Compliance Officer

Date: 6/5/2012

FIELD OFFICE MANAGER DETERMINATION

Field Office Manager review required

NCO REQUESTS THE FIELD OFFICE MANAGER REVIEW FOR THE FOLLOWING REASON:

- Proposed action fits within a categorical exclusion but involves a high profile or controversial issue that warrants Field Office Manager's attention.
- Proposed action falls within an EA or EIS category and therefore requires Field Office Manager's review and determination.

BASED ON MY REVIEW I CONCUR WITH THE DETERMINATION OF THE NCO :

Field Office Manager's Signature: _____

Field Office Manager

Date: _____