

**BEFORE THE
U.S. DEPARTMENT OF ENERGY
Washington, D.C. 20585**

In the Matter of:

Cooper Power Systems, LLC
(distribution transformers)

Case Number: 2017-SE-47003

Issued: September 27, 2017

NOTICE

This Notice corrects an error in the Notice of Noncompliance Determination issued in this case on August 28, 2017.

On August 28, 2017, the Department of Energy (“DOE”) issued a Notice of Noncompliance Determination (“Noncompliance Determination”) to Cooper Power Systems, LLC (“Cooper”), a wholly-owned subsidiary of Cooper Industries, finding that 229 basic models of distribution transformers do not comply with the applicable federal energy conservation standards.

The Noncompliance Determination incorrectly stated that the distribution transformers were low-voltage distribution transformers subject to federal energy conservation standards as described in 10 C.F.R. § 431.196(a); however, the basic models identified are liquid-immersed distribution transformers and subject to federal energy conservation standards as described in 10 C.F.R. § 431.196(b).

Cooper is not required to take any additional action as a result of this Notice.

_____/S/_____
Laura L. Barhydt
Assistant General Counsel
for Enforcement