From: Michael Regulinski
To: Batra, Rakesh
Cc: Pincus, Steven; Bryson, Mike E.; Souder, David W.; Tam, Simon K.; "craig.glazer@pjm.com"; McGlynn, Paul; Bresler, Frederick S. (Stu) III
Subject: FW: Emergency Order Pursuant to FPA 202(c) - Renewal Due date approaching
Date: Tuesday, September 05, 2017 11:04:06 AM

Rakesh, here is the information you requested regarding Yorktown Units 1 and 2. Please let me know if you have further questions. Mike

	Yorktown 1	Yorktown 2
Name plate (kVA)	200,535	218,000
Min Real Output (MW)	85.0	85.0
Max Real Output (MW)	159.0	164.0
Lagging MVAr	65.0	81.0
Leading MVAr	-50.0	-48.0
Ramp up/down (MW/Min)	1.0	1.4
Operational Limits (MW)	135.0	135.0

Michael C. Regulinski
Managing General Counsel

Dominion Energy Services, Inc.
tieline: 738-2794
P: (804) 819-2794
C: (804) 921-3108
michael.regulinski@dominionenergy.com

From: Batra, Rakesh [mailto:Rakesh.Batra@Hq.Doe.Gov]
Sent: Thursday, August 24, 2017 11:28 AM
To: Pincus, Steven; Michael Regulinski (Services - 6); Bryson, Mike E.; Souder, David W.; Tam, Simon K.
Cc: Glazer, Craig; McGlynn, Paul; Bresler, Frederick S. (Stu) III
Subject: [External] RE: Emergency Order Pursuant to FPA 202(c) - Renewal Due date approaching

PJM /Dominion:

Could you please provide us the name plate rating, Min & Max Real and reactive power outputs, Ramp up and down time and any operational limits for both the coal units at Yorktown location?

Thanks,
Rakesh

CONFIDENTIALITY NOTICE: This electronic message contains information which may be legally confidential and or privileged and does not in any case represent a firm ENERGY COMMODITY bid or offer relating thereto which binds the sender without an additional express written confirmation to that effect. The information is intended solely for the individual or entity named above and access by anyone else is unauthorized. If you are not the intended recipient, any disclosure, copying, distribution, or use of the contents of this information is prohibited and may be unlawful. If you have received this electronic transmission in error, please reply immediately to the sender that you have received the message in error, and delete it. Thank you.