From:	Michael Regulinski
To:	Batra, Rakesh
Cc:	Pincus, Steven; Bryson, Mike E.; Souder, David W.; Tam, Simon K.; "craig.glazer@pjm.com"; McGlynn, Paul; Bresler, Frederick S. (Stu) III
Subject:	RE: Emergency Order Pursuant to FPA 202(c) - Renewal Due date approaching
Date:	Friday, October 27, 2017 2:48:36 PM

Rakesh, you requested an explanation of the difference between the operational limits for Yorktown Units 1 and 2 which were lowered to 135 MW each, effective in June, 2017, and the MW output levels shown in the Yorktown July 2017 Run Time report for the July 11-25 runs directed by PJM and reported to DOE on August 24, which exceeded 135 MWs on several occasions.

The MW values provided in the Yorktown Run Time report for the July runs reflect the gross values of plant MW output. Emission data is determined on gross MW values. The 135 MW operational limit reflects the net MW output of the plant, which is the gross output of the units reduced by station auxiliary power, which is the power needed to operate the station itself and the generation units.

Please let me know if you have additional questions. Mike

Michael C. Regulinski
Managing General Counsel

Dominion Energy Services, Inc.
tieline: 738-2794
P: (804) 819-2794
C: (804) 921-3108
michael.regulinski@dominionenergy.com

From: Michael Regulinski (Services - 6)
Sent: Wednesday, October 25, 2017 4:37 PM
To: 'Batra, Rakesh'
Cc: Pincus, Steven; Bryson, Mike E.; Souder, David W.; Tam, Simon K.; 'craig.glazer@pjm.com'; McGlynn, Paul; Bresler, Frederick S. (Stu) III
Subject: RE: Emergency Order Pursuant to FPA 202(c) - Renewal Due date approaching

Rakesh, as we discussed on the phone, we found our response to the September 5 email. I will ask management about the difference between the operational limits shown in our email response and the MW output levels shown in the August 24 Yorktown Run Time report for the July runs.

Thanks,

Michael C. Regulinski
Managing General Counsel

Dominion Energy Services, Inc.
tieline: 738-2794

P: (804) 819-2794
C: (804) 921-3108
michael.regulinski@dominionenergy.com

From: Batra, Rakesh [mailto:Rakesh.Batra@Hq.Doe.Gov]
Sent: Wednesday, October 25, 2017 3:53 PM
To: Michael Regulinski (Services - 6)
Cc: Pincus, Steven; Bryson, Mike E.; Souder, David W.; Tam, Simon K.; 'craig.glazer@pjm.com'; McGlynn, Paul; Bresler, Frederick S. (Stu) III
Subject: [External] RE: Emergency Order Pursuant to FPA 202(c) - Renewal Due date approaching

For some reason the below email from September 5, 2017, was not responded. Could you please provide/clarify the definition of operational limit?

Thanks,
Rakesh

From: Batra, Rakesh
Sent: Tuesday, September 05, 2017 11:40 AM
To: 'Michael Regulinski' <michael.regulinski@dominionenergy.com>
Cc: Pincus, Steven <Steven.Pincus@pjm.com>; Bryson, Mike E. <Michael.Bryson@pjm.com>; Souder, David W. <David.Souder@pjm.com>; Tam, Simon K. <Simon.Tam@pjm.com>; 'craig.glazer@pjm.com' <craig.glazer@pjm.com>; McGlynn, Paul <Paul.McGlynn@pjm.com>; Bresler, Frederick S. (Stu) III <Stu.Bresler@pjm.com>
Subject: RE: Emergency Order Pursuant to FPA 202(c) - Renewal Due date approaching

Could you please clarify the definition of operational limit?
Thanks,
Rakesh

From: Michael Regulinski [mailto:michael.regulinski@dominionenergy.com]
Sent: Tuesday, September 05, 2017 11:04 AM
To: Batra, Rakesh <Rakesh.Batra@Hq.Doe.Gov>
Cc: Pincus, Steven <Steven.Pincus@pjm.com>; Bryson, Mike E. <Michael.Bryson@pjm.com>; Souder, David W. <David.Souder@pjm.com>; Tam, Simon K. <Simon.Tam@pjm.com>; 'craig.glazer@pjm.com' <craig.glazer@pjm.com>; McGlynn, Paul <Paul.McGlynn@pjm.com>; Bresler, Frederick S. (Stu) III <Stu.Bresler@pjm.com>
Subject: FW: Emergency Order Pursuant to FPA 202(c) - Renewal Due date approaching

Rakesh, here is the information you requested regarding Yorktown Units 1 and 2. Please let me know if you have further questions. Mike

	Yorktown 1	Yorktown 2
Name plate (kVA)	200,535	218,000
Min Real Output (MW)	85.0	85.0
Max Real Output (MW)	159.0	164.0
Lagging MVAr	65.0	81.0
Leading MVAr	-50.0	-48.0
Ramp up/down (MW/Min)	1.0	1.4
Operational Limits (MW)	135.0	135.0

Michael C. Regulinski
Managing General Counsel

Dominion Energy Services, Inc.
tieline: 738-2794
P: (804) 819-2794
C: (804) 921-3108
michael.regulinski@dominionenergy.com

From: Batra, Rakesh [mailto:Rakesh.Batra@Hq.Doe.Gov]
Sent: Thursday, August 24, 2017 11:28 AM
To: Pincus, Steven; Michael Regulinski (Services - 6); Bryson, Mike E.; Souder, David W.; Tam, Simon K.
Cc: Glazer, Craig; McGlynn, Paul; Bresler, Frederick S. (Stu) III
Subject: [External] RE: Emergency Order Pursuant to FPA 202(c) - Renewal Due date approaching

PJM /Dominion:

Could you please provide us the name plate rating, Min & Max Real and reactive power outputs, Ramp up and down time and any operational limits for both the coal units at Yorktown location?

Thanks,
Rakesh

CONFIDENTIALITY NOTICE: This electronic message contains information which may be legally confidential and or privileged and does not in any case represent a firm ENERGY COMMODITY bid or offer relating thereto which binds the sender without an additional express written confirmation to that effect. The information is intended solely for the individual or entity named above and access by anyone else is unauthorized. If you are not the intended recipient, any disclosure, copying, distribution, or use of the contents of this information is prohibited and may be unlawful. If you have received this

electronic transmission in error, please reply immediately to the sender that you have received the message in error, and delete it. Thank you.

CONFIDENTIALITY NOTICE: This electronic message contains information which may be legally confidential and or privileged and does not in any case represent a firm ENERGY COMMODITY bid or offer relating thereto which binds the sender without an additional express written confirmation to that effect. The information is intended solely for the individual or entity named above and access by anyone else is unauthorized. If you are not the intended recipient, any disclosure, copying, distribution, or use of the contents of this information is prohibited and may be unlawful. If you have received this electronic transmission in error, please reply immediately to the sender that you have received the message in error, and delete it. Thank you.