

**U.S. Department of Energy  
Naval Reactors Representative's Office  
Kesselring Site**

National Environmental Policy Act (NEPA) Categorical Exclusion (CX)  
Determination Summary Form

**KESSELRING SITE HEAD TANKS CORROSION PROTECTION PROJECT**

**REFERENCE**

10 CFR Part 1021, Department of Energy National Environmental Policy Act Implementing Procedures, Subpart D, Typical Classes of Actions

**PROJECT SCOPE DISCUSSION**

The Kesselring Site Head Tanks Corrosion Protection Project includes work to Head Tanks (27A and 27B) for repairs to the interior iron oxide urethane coating and aliphatic urethane exterior coating systems, replacement of a water valve and roof vents, and installation of manway entrances and Impressed Current Cathodic Protection (ICCP) systems.

The project does not violate any applicable regulatory requirements, require construction or major expansion of waste handling facilities, result in unpermitted releases of hazardous substances, or adversely affect environmentally sensitive resources, including wetlands. The project does not involve genetically engineered organisms or species. There are no extraordinary circumstances related to the proposed action. The project has not been segmented to meet the definition of a categorical exclusion and is not connected to other actions with potentially significant and/or cumulative impacts.

**CONCLUSION**

The Kesselring Site Head Tanks Corrosion Protection Project is categorically excluded from additional NEPA documentation under 10 CFR 1021 Subpart D, Appendix B1.3. Specifically, the categorical exclusion that applies is:

**B1.3 Routine Maintenance**

Routine maintenance activities and custodial services for buildings, structures, rights-of-way, infrastructures (e.g., pathways, roads, and railroads), vehicles and equipment, and localized vegetation and pest control, during which operations may be suspended and resumed. Custodial services are activities to preserve facility appearance, working conditions, and sanitation, such as cleaning, window washing, lawn mowing, trash collection, painting, and snow removal. Routine maintenance activities, corrective (that is, repair), preventive, and predictive, are required to maintain and preserve buildings, structures, infrastructures, and equipment in a condition suitable for a facility to be used for its designated purpose. Routine maintenance may result in replacement to the extent that replacement is in kind and is not a substantial upgrade or improvement. In kind replacement includes installation of new components to replace outmoded components if the replacement does not result in a significant change in the expected useful life,

design capacity, or function of the facility. Routine maintenance does not include replacement of a major component that significantly extends the originally intended useful life of a facility (for example, it does not include the replacement of a reactor vessel near the end of its useful life). Routine maintenance activities include, but are not limited to:

- (a) Repair of facility equipment, such as lathes, mills, pumps, and presses;
- (b) Door and window repair or replacement;
- (c) Wall, ceiling, or floor repair;
- (d) Reroofing;
- (e) Plumbing, electrical utility, and telephone service repair;
- (f) Routine replacement of high-efficiency particulate air filters;
- (g) Inspection and/or treatment of currently installed utility poles;
- (h) Repair of road embankments;
- (i) Repair or replacement of fire protection sprinkler systems;
- (j) Road and parking area resurfacing, including construction of temporary access to facilitate resurfacing;
- (k) Erosion control and soil stabilization measures (such as reseeding and revegetation)
- (l) Surveillance and maintenance of surplus facilities in accordance with DOE Order 5820.2, "Radioactive Waste Management";
- (m) Repair and maintenance of transmission facilities, including replacement of conductors of the same nominal voltage, poles, circuit breakers, transformers, capacitors, crossarms, insulators, and downed transmission lines, in accordance, where appropriate, with 40 CFR part 761 (Polychlorinated Biphenyls Manufacturing, Processing, Distribution in Commerce, and Use Prohibitions);
- (n) Routine testing and calibration of facility components, subsystems, or portable equipment (including but not limited to, control valves, in-core monitoring devices, transformers, capacitors, monitoring wells, lysimeters, weather stations, and flumes);
- (o) Routine decontamination of the surfaces of equipment, rooms, hot cells, or other interior surfaces of buildings (by such activities as wiping with rags, using strippable latex, and minor vacuuming), including removal of contaminated intact equipment and other materials (other than spent nuclear fuel or special nuclear material in nuclear reactors)
- (p) Removal of debris.

NRRO Approval:



H. S. Miller

Date:

10 DEC 2020

CX Determination Date