

Categorical Exclusion Determination

Western Area Power Administration
Department of Energy



Proposed Action: Folsom-Roseville 2/2 Off-ROW Willow Removal

Project No.: 100153025

Project Manager: Ricardo Velarde

Location: 9824 Hopkins Ct, Granite Bay, CA

Categorical Exclusion Applied (from Subpart D, 10 C.F.R. Part 1021): B1.3 Routine maintenance

Description of the Proposed Action:

Western Area Power Administration, Sierra Nevada Region (WAPA) is responsible for the operation and maintenance of several federally owned and operated transmission lines throughout California, including Folsom-Roseville 230-kV line (FOL-RSC), located in Placer and Sacramento counties. Part of this responsibility includes ensuring WAPA maintains reliable access to transmission towers and other facilities to comply with the National Electric Safety Code, Western States Coordinating Council, and WAPA directives for protecting human safety and maintaining the reliable operation of the transmission system.

WAPA proposes to remove one multi-stem Willow tree on the north side of the right-of-way (ROW) between towers 2/2 and 2/3 at the rear of 9824 Hopkins Court. This is one tree that is outside of the ROW and therefore is not covered under the 2005 Sacramento Valley Right-of-Way Maintenance Program (Sacramento Valley Program) EA. Additional trees and vegetation removal will be conducted within the ROW and covered under the EA.

The hazard tree is located outside but adjacent to the right-of-way (off-ROW) and has the potential to fall on, grow into, or otherwise compromise the integrity of the transmission lines. WAPA Order 450.3A dictates the removal of hazard trees in compliance with the North American Electric Reliability Council (NERC) Standard FAC-003-1. WAPA has limited discretion on the removal of trees that meet hazard standards. All wood and debris will be hauled off site and not disposed of in a landfill. Remaining stump will be treated with WAPA herbicide recommendation.

Findings:

In accordance with Section 1021.410(b) of the Department of Energy's (DOE) National Environmental Policy Act (NEPA) Regulations (57 FR 15144, Apr. 24, 1992, as amended at 61 FR 36221-36243, Jul. 9, 1996; 61 FR 64608, Dec. 6, 1996, 76 FR 63764, Nov. 14, 2011), WAPA has determined that the proposed action:

- (1) fits within a class of actions listed in Appendix B of 10 CFR 1021, Subpart D (see attached Environmental Checklist);
- (2) does not present any extraordinary circumstances that may affect the significance of the environmental effects of the proposal; and
- (3) has not been segmented to meet the definition of a categorical exclusion.

Based on these determinations, WAPA finds that the proposed action is categorically excluded from further NEPA review.

Signed: Latisha M. Saare

Digitally signed by Latisha M. Saare
Date: 2021.01.28 10:34:13 -08'00'

Date: 1/28/21

Attachment: Environmental Checklist

Categorical Exclusion Environmental Checklist

This checklist documents environmental considerations for the proposed project and explains why the project would not have the potential to cause significant impacts on environmentally sensitive resources and would meet other integral elements of the applied categorical exclusion.

Proposed Action: Folsom-Roseville 2/2 Off-ROW Willow Removal

Project Site Description

The proposed project area is in Placer County, California.

The dominant habitat at this site consists of ornamental trees within suburban backyard.

Equipment staging areas would be on roads and within the ROW whenever possible.

Evaluation of Potential Impacts to Environmental Resources

Environmental Resource Impacts	No Potential for Significance	No Potential for Significance, with Conditions
1. Historic and Cultural Resources <u>Explanation:</u>	<input checked="" type="checkbox"/>	<input type="checkbox"/>

Tree removal will not cause significant ground disturbance. The O&M activities and vegetation management at these sites would not impact cultural resources. Natural Resources will be contacted immediately if archeological, paleontological, or historic evidence is found.

2. **Geology and Soils**



Explanation:

Ground disturbance is not anticipated in this project; therefore, no impacts would occur.

3. **Plants** (including Federal/state special-status species and habitats)



Explanation:

No special-status plants are known or expected in the project area. The site is a suburban neighborhood. Construction vehicles and equipment would be required to be clean before entering the project location to prevent spread of invasive weeds.

4. **Wildlife** (including Federal/state special-status species and habitats)



Explanation:

No special status wildlife is known or expected in the project area.

The project areas was surveyed for migratory birds and other potential wildlife on January 26, 2021. No species of concern or nests were observed.

5. **Water Bodies, Floodplains, and Fish** (including Federal/state special-status species, ESUs, and habitats)



Explanation:

The project area was surveyed for water resources on January 26, 2021. No water resources occur within the project area.

6. **Wetlands**
Explanation:



The project area was surveyed for wetland resources on January 26, 2021. No wetland resources occur within the project area.

7. **Groundwater and Aquifers**
Explanation:



Spill prevention measures would be utilized during construction activities. The project would not provide a pathway for groundwater contamination.

8. **Land Use and Specially-Designated Areas**
Explanation:



The land use would not change at the project site. Nor is the project within, or near, any specially designated areas, such as National Scenic Rivers.

9. **Visual Quality**
Explanation:



The visual quality would be consistent with the existing use of the transmission right-of-way corridor. There would be no significant change to the visual quality.

10. **Air Quality**
Explanation:



A small amount of dust and vehicle emissions would occur during tree removal; however, there would be no significant changes to air quality during or after construction.

The project location is located in a distressed air basin. This section describes procedures adopted by WAPA to support the state implementation plan to restore air quality in the region. The contractor is expected to adopt the procedures during the project.

AQ-SOP-1: The Contractor will adhere to all applicable requirements of those agencies having jurisdiction over air quality matters, and any necessary permits for O&M will be obtained.

AQ-SOP-2: Machinery and vehicles will be kept in good operating condition and older equipment will be replaced with equipment meeting applicable emission standards; appropriate emissions-control equipment will be maintained for vehicles and equipment, per EPA and/or WAPA air-emission requirements.

AQ-SOP-3: Idle equipment will be shut down when not in active use; visible emissions from stationary generators will be controlled.

AQ-SOP-4: Dust –control measures will be implemented in road construction and maintenance, as needed.

Trucks transporting loose material will be covered or maintain at least two feet of freeboard and will not create any visible dust emissions.

AQ-SOP-5: There will be no open burning of construction trash.

AQ-SOP-6: Grading activities will cease during periods of high winds (as determined by local air quality management districts).

AQ-SOP-7: Major operations will be avoided on days when the local Air Quality Index is expected to exceed 150.

11. **Noise**



Explanation:

There are residences within the project location. Tree removal construction noise would be temporary and would occur during daylight hours. Operational noise would not change.

12. **Human Health and Safety**



Explanation:

During project activities, all standard safety protocols would be followed. Project activities would not impact human health or safety. Contractor shall be required to follow the OSHA standards set forth in 29 CFR 1910.269 specifically paragraphs (a)(2), (b), (c), (g), (k), (p), and (r) as required under (a)(E)(2). Line-clearance tree trimming operations performed by line-clearance tree trimmers who are not qualified employees. Contractor shall also adhere to the requirements under Title 8 Cal OSHA Electrical Safety Order specifically Subchapter 5 Article 38 and Subchapter 7 Article 12. Contractor shall maintain a safe working distance from conductors as described in the above OSHA standards. If a safe working distance cannot be maintained, a clearance shall be requested 3 days in advance.

Evaluation of Other Integral Elements

The proposed project would also meet conditions that are integral elements of the categorical exclusion. The project would not:

- Threaten a violation of applicable statutory, regulatory, or permit requirements for environment, safety, and health, or similar requirements of DOE or Executive Orders.

Explanation, if necessary:

- Require siting and construction or major expansion of waste storage, disposal, recovery, or treatment facilities (including incinerators) that are not otherwise categorically excluded.

Explanation, if necessary:

- Disturb hazardous substances, pollutants, contaminants, or CERCLA excluded petroleum and natural gas products that preexist in the environment such that there would be uncontrolled or unpermitted releases.

Explanation, if necessary:

- Involve genetically engineered organisms, synthetic biology, governmentally designated noxious weeds, or invasive species, unless the proposed activity would be contained or confined in a manner designed and operated to prevent unauthorized release into the environment and conducted in accordance with applicable requirements, such as those of the Department of Agriculture, the Environmental Protection Agency, and the National Institutes of Health.

Explanation, if necessary:

Landowner Notification, Involvement, or Coordination

Description: WAPA would work closely with the landowners to provide adequate notification of vegetation work schedules.

Based on the foregoing, this proposed project does not have the potential to cause significant impacts to any environmentally sensitive resource.

Signed: **Latisha M. Saare**

Digitally signed by Latisha M. Saare
Date: 2021.01.28 10:35:15 -08'00'

Date: 1/28/21