

DOE Transmission Reliability R&D Program

Distribution-Level Impacts of Plug-in Electric Vehicle Charging on the Transmission System during Fault Conditions

DOE Dynamic Load Modeling Working Group

March 24, 2022

Presented by:

Joseph H. Eto, Lawrence Berkeley National Laboratory – jheto@lbl.gov

Project Team:

Frank Tuffner, Pacific Northwest National Laboratory

Don Scoffield, Idaho National Laboratory


John Undrill, Arizona State University

Dmitry Kosterev, Bonneville Power Administration

Ryan Quint, North American Electric Reliability Corporation



Electricity Consumption by Plug-in Electric Vehicle (PEVs) is Projected to Grow



Source: ISO-NE. 2021 Final Electrification Transportation Forecast



Study Objectives

To provide engineering counterparts in the PEV and electric vehicle supply equipment industry with insights into the types of PEV charging behaviors that are grid friendly or grid unfriendly during transmission faults

To show the range of grid friendly and grid unfriendly behaviors that currently exist in a selection of PEVs that are in production today



The image shows the cover of a technical report. At the top left is the Pacific Northwest National Laboratory logo, which consists of an orange stylized bird or wing shape above the text 'Pacific Northwest NATIONAL LABORATORY'. Below the logo, the report number 'PNNL-31558' is printed. The main title of the report is 'Distribution-Level Impacts of Plug-in Electric Vehicle Charging on the Transmission System during Fault Conditions', written in a bold, orange font. Below the title, the date 'October 2021' is listed. The authors are: Frank Tuffner, John Undrill¹, Don Scofield², Joseph Eto³, Dmitry Kosterev⁴, and Ryan Quint⁵. At the bottom, there is a small logo for the U.S. Department of Energy and text indicating the report was prepared for the U.S. Department of Energy under Contract DE-AC05-76RL01830. A list of footnotes at the bottom identifies the affiliations: 1 Arizona State University, 2 Idaho National Laboratory, 3 Lawrence Berkeley National Laboratory, 4 Bonneville Power Administration, and 5 North American Electric Reliability Corporation.

Pacific Northwest
NATIONAL LABORATORY

PNNL-31558

**Distribution-Level
Impacts of Plug-in
Electric Vehicle Charging
on the Transmission
System during Fault
Conditions**

October 2021

Frank Tuffner
John Undrill¹
Don Scofield²
Joseph Eto³
Dmitry Kosterev⁴
Ryan Quint⁵

U.S. DEPARTMENT OF
ENERGY

Prepared for the U.S. Department of Energy
under Contract DE-AC05-76RL01830



1 Arizona State University
2 Idaho National Laboratory
3 Lawrence Berkeley National Laboratory

4 Bonneville Power Administration
5 North American Electric Reliability Corporation

Study Approach

Residential AC stalling (FIDVR) is a known example of a *grid unfriendly* load (<http://fidvr.lbl.gov>)

This Study examines the impacts of PEV charging on FIDVR



Topology and Properties of R1-12.47-1 feeder

Property	Value
Overall Information	
Geographic Area	11.75 square miles
Base Load	5.57 megawatts
Load Composition	
Residential	93.4%
Commercial	5.7%
Agricultural	0.9%
Distribution Line Lengths	
Overhead Line	14.24 miles
Underground Line	11.35 miles
Triplex (service) Line	3.40 miles

PEVs that make FIDVR worse are *grid unfriendly*

PEVs that do not make FIDVR worse are *grid friendly*



Study Method



The impacts of transmission faults on voltages within the distribution feeder are studied using GridLAB-D

The behavior of single-phase induction motors is represented in GridLAB-D using a dynamic-phasor-based model

The impacts of step changes in distribution voltages on PEV charging are studied using Caldera

Caldera is a model with 4 states and 3 transitions. Parameters were estimated through lab testing of commercially available PEVs (circa 2015 vintage)

Co-simulation of GridLAB-D and Caldera is managed through the HELICS platform



Step Change in pu Voltage	Probability of Transition A1	Probability of Transition A2
0.15	0.2	0
0.2	0.4	0
0.3	0.8	0
0.4	1	0.5
0.5	1	1



Baseline FIDVR Results – No PEVs

A range of transmission faults are “played into” GridLAB-D


The number of residential AC units that stall are tabulated (there are a total of 331 residential AC units on this phase of the feeder)

These values represent the baseline against which PEV impacts will be compared


Depth of Voltage Dip	Duration of Voltage Dip			
	5 cycles	7 cycles	9 cycles	12 cycles
0.55	0	0	0	272
0.5	0	0	199	331
0.45	0	0	331	331

Note: In our simulations, all residential AC units re-accelerate eventually; none remain stalled and trip off due to internal thermal protection

Residential Air Conditioner Operating States – 9-cycle voltage dip to 0.50 pu




Residential Air Conditioner Operating States – 12-cycle voltage dip to 0.50 pu





Baseline Results – No PEVs

Residential AC Motor Speeds – 9-cycle voltage dip to 0.50 pu



The number of residential AC units that stall initially, re-accelerate, or remain stalled depends on the voltage they see, which varies by location within the distribution feeder

Voltages at Selected Locations – 9-cycle voltage dip to 0.50 pu




Impact of PEVs on FIDVR

We now add a single type of PEV to every household within the distribution feeder and re-run the transmission fault scenarios

We tabulate the number of residential AC units that stall initially and also those that remain stalled 2 seconds after the fault has cleared

These values represent the impacts of each type of PEV on FIDVR at two different points in time

We studied six types of PEVs; we normalized their ratings to facilitate comparisons



Effect of PEVs on Initial Number of AC Units that Stall during a Fault

#	Fault Scenario		Initial Number of Units Stalled (increase/decrease from baseline)					
	Depth	Duration	EV-A	EV-B	EV-C	EV-D	EV-E	EV-F
1	0.55	5	0	0	0	0	0	0
2	0.55	7	100	0	72	0	0	0
3	0.55	9	330	0	320	167	309	0
4	0.55	12	59	-232	59	59	59	-38
5	0.5	5	0	0	0	0	0	0
6	0.5	7	309	0	309	35	260	0
7	0.5	9	132	-199	132	132	132	-199
8	0.5	12	0	0	0	0	0	0
9	0.45	5	0	0	0	0	0	0
10	0.45	7	302	-29	302	280	302	-29
11	0.45	9	0	0	0	0	0	0
12	0.45	12	0	0	0	0	0	0


Grid Unfriendly

Grid Friendly



EV-B is a Grid Friendly PEV during Faults


Residential AC Motor Speeds **No PEV** – 9-cycle voltage dip to 0.50 pu




EV-B is grid friendly because it ceases consuming current at the onset of the fault

By taking PEV load off the distribution feeder, residential AC units are able to re-accelerate more quickly

Residential AC Motor Speeds **with EV-B** – 9-cycle voltage dip to 0.50 pu



Operating States of **EV-B** – 9-cycle voltage dip to 0.50 pu




EV-A is a **Grid Unfriendly** PEV during Faults


EV-A is grid unfriendly because it does not cease consuming current at the onset of and through the duration of the fault

By keeping PEV load on the distribution feeder, residential AC units are not able to re-accelerate


Operating States of **EV-A** – 9-cycle voltage dip to 0.50 pu



Residential AC Motor Operating States **No PEV** – 9-cycle voltage dip to 0.50 pu



Residential AC Motor Operating States **with EV-A** – 9-cycle voltage dip to 0.50 pu



Effect of PEVs on Number of AC Units that Remain Stalled 2 seconds after Fault has Cleared

#	Fault Scenario		Number of Units Stalled at $T_{\text{Fault}}+2.0\text{s}$ (increase/decrease from baseline)					
	Depth	Duration	EV-A	EV-B	EV-C	EV-D	EV-E	EV-F
1	0.55	5	0	0	0	0	0	0
2	0.55	7	0	0	0	0	0	0
3	0.55	9	291	0	307	0	300	0
4	0.55	12	291	0	307	0	303	0
5	0.5	5	0	0	0	0	0	0
6	0.5	7	272	0	295	0	256	0
7	0.5	9	291	0	307	0	300	0
8	0.5	12	291	0	305	0	300	0
9	0.45	5	0	0	0	0	0	0
10	0.45	7	297	0	301	0	295	0
11	0.45	9	303	0	307	0	300	0
12	0.45	12	307	0	307	0	300	0

Grid Unfriendly

Grid Friendly




EV-D was a **Grid Unfriendly** PEV during the Fault, but was **Grid Friendly** after the Fault

EV-D was grid unfriendly because it did not cease consuming current at through the duration of the fault


EV-D became grid friendly because it ceased consuming current after the fault

By taking PEV load off the distribution feeder, residential AC units were able to re-accelerate


Residential AC Motor Operating States **No PEV** – 9-cycle voltage dip to 0.50 pu




Residential AC Motor Operating States **with EV-D** – 9-cycle voltage dip to 0.50 pu



Operating States of **EV-D** – 9-cycle voltage dip to 0.50 pu



Grid Friendly and Grid Unfriendly PEV Behaviors



Next Steps

Present and discuss findings with engineering counterparts in the PEV and electric vehicle supply equipment industry

Explore opportunities to develop standards (IEEE and SAE) that establish technical performance requirements and testing protocols for electronically-coupled end-use loads connected to the grid through power electronic interfaces

Demonstrate the usefulness of study approaches such as these for supporting enhancements to the composite load model to better capture the diversity and growth in power electronic loads

