U.S. Department of Energy Naval Reactors Laboratory Field Office

Naval Reactors Facility

National Environmental Policy Act (NEPA) Categorical Exclusion (CX)

Determination Summary Form

NAVAL REACTORS FACILITY BACKUP POWER UPGRADE PROJECT

REFERENCE

10 CFR Part 1021, Department of Energy, National Environmental Policy Act Implementing Procedures, Subpart D, Typical Classes of Actions

PROJECT SCOPE DISCUSSION

The Naval Reactors Facility (NRF) currently has emergency diesel generators (EDGs) that provide backup power to support site systems in the event of a loss of commercial power. However, future power demands will exceed the capacity of the current EDGs. In lieu of adding another EDG, NRF will utilize the current EDGs as efficiently as possible by rerouting the electrical infrastructure to support critical systems during a power outage.

The scope of the project includes modifying the current electrical system to manage the electrical loads more efficiently. The upgrades and modifications will separate the critical systems that require backup power from the non-critical systems. In order to facilitate modification of the current electrical infrastructure, new electrical equipment will be installed within several of the buildings on-site and current equipment will be upgraded or removed.

Work will also include tying into the existing underground duct bank north of NRF-692. The work will require soil excavation and electrical equipment installation.

The Backup Power Upgrade Project does not violate applicable regulatory requirements, require construction or major expansion of waste handling facilities, result in unpermitted releases of hazardous substances, or adversely affect environmentally sensitive resources, including wetlands. The project does not involve genetically engineered organisms or species. There are no extraordinary circumstances related to the proposed action. The project has not been segmented to meet the definition of a categorical exclusion and is not connected to other actions with potentially significant and/or cumulative impacts.

CONCLUSION

The NRF Backup Power Upgrade Project is categorically excluded from the additional NEPA documentation under 10 CFR 1021 Subpart D, Appendix B, as follows:

B1.3 Routine Maintenance

"Routine maintenance activities and custodial services for buildings, structures, rights-of-way, infrastructures (including, but not limited to, pathways, roads, and railroads), vehicles and equipment, and localized vegetation and pest control, during which operations may be suspended and resumed, provided that the activities would be conducted in a manner in accordance with applicable requirements. Custodial services are activities to preserve facility appearance, working conditions, and sanitation (such as cleaning, window washing, lawn mowing, trash collection, painting, and snow removal). Routine maintenance activities, corrective (that is, repair), preventive, and predictive, are required to maintain and preserve buildings, structures, infrastructures, and equipment in a condition suitable for a facility to be used for its designated purpose. Such maintenance may occur as a result of severe weather (such as hurricanes, floods, and tornados), wildfires, and other such events.

Routine maintenance may result in replacement to the extent that replacement is inkind and is not a substantial upgrade or improvement. In-kind replacement includes installation of new components to replace outmoded components, provided that the replacement does not result in a significant change in the expected useful life, design capacity, or function of the facility. Routine maintenance does not include replacement of a major component that significantly extends the originally intended useful life of a facility (for example, it does not include the replacement of a reactor vessel near the end of its useful life). Routine maintenance activities include, but are not limited to:

- (a) Repair or replacement of facility equipment, such as lathes, mills, pumps, and presses;
- (b) Door and window repair or replacement;
- (c) Wall, ceiling, or floor repair or replacement;
- (d) Reroofing;
- (e) Plumbing, electrical utility, lighting, and telephone service repair or replacement;
- (f) Routine replacement of high-efficiency particulate air filters;
- (g) Inspection and/or treatment of currently installed utility poles;
- (h) Repair of road embankments;
- (i) Repair or replacement of fire protection sprinkler systems;
- Road and parking area resurfacing, including construction of temporary access to facilitate resurfacing, and scraping and grading of unpaved surfaces;
- (k) Erosion control and soil stabilization measures (such as reseeding, gabions, grading, and revegetation);
- Surveillance and maintenance of surplus facilities in accordance with DOE Order 435.1, "Radio

- (m) active Waste Management," or its successor;
- (n) Repair and maintenance of transmission facilities, such as replacement of conductors of the same nominal voltage, poles, circuit breakers, transformers, capacitors, crossarms, insulators, and downed powerlines, in accordance, where appropriate, with 40 CFR part 761 (Polychlorinated Biphenyls Manufacturing, Processing, Distribution in Commerce, and Use Prohibitions) or its successor;
- (o) Routine testing and calibration of facility components, subsystems, or portable equipment (such as control valves, in-core monitoring devices, transformers, capacitors, monitoring wells, lysimeters, weather stations, and flumes);
- (p) Routine decontamination of the surfaces of equipment, rooms, hot cells, or other interior surfaces of buildings (by such activities as wiping with rags, using strippable latex, and minor vacuuming), and removal of contaminated intact equipment and other material (not including spent nuclear fuel or special nuclear material in nuclear reactors); and
- (q) Removal of debris."

B1.27 Disconnection of Utilities

"Activities that are required for the disconnection of utility services (including, but not limited to, water, steam, telecommunications, and electrical power) after it has been determined that the continued operation of these systems is not needed for safety."

NRLFO Approval: C. M. Henvit CX Determination