## **Cost Compression of Heat Pump Water Heaters for Multifamily Housing in Cold Climates (CC HPWH MH CC)**

Centralized System

50-gallor Basement Drain **AOSmith CAK RIDGE** National Laboratory Argonne 🕰 NATIONAL LABORATOR Innovation has a name

Unitary HPWH Solution

Oak Ridge National Lab Kashif Nawaz (Senior R&D Staff) (865) 241-0972 nawazk@ornl.gov Joseph Rendall (Associate R&D Staff) (865) 341-0422 rendalljd@ornl.gov WBS 03.02.02.60, FY 22 ET Lab Call Small

**EWHs** 

Hybrid HPWHs System With

Sewer Heat Recovery

Gary Klein and Associates, Inc "Where water and energy connect"

## **Project Summary**

Hybrid HPWHs System With Sewer Heat Recovery

#### **Objective and outcome**

Design and pilot-demonstration of an equitable HPWH solution for low-income multifamily housing in cold climates to:

- achieve 30% cost reduction, with
- 25% available hot water increase
- up to 1,000 times reduction in EOL  $CO_2$  compared state-of-the-art HPWHs using R134a.

### Team and Partners









#### <u>Stats</u>

**New Project** 

Performance Period: 01/2023 – 01/2026 DOE budget: \$2,400k Cost Share: Confidential Milestone 1 (Y23): Cost effective system design for low-income multifamily units modeled Milestone 2 (Y24): Experimentally validate design for low-income multifamily units Milestone 3 (Y25): Demonstrate design in pilot study

Small EWHs

## **Problem Statement**

Current technologies for energy-efficient water heating in multifamily housing in cold climates have challenges:

- <u>High Initial cost:</u> Unitary Air Source-HPWH premium costs over unitary electric resistance water heater (ERWH) is \$1,300
- <u>Space restriction:</u> Venting a water heater closet in an existing multifamily unit to prevent the AS-HPWH additional space heating load is costly
- Lower Energy Performance: When vented with ambient, COP of Air Source-HPWH reduces to < 2 at colder air temperatures

### **Proposed Solution**

### Water Source-HPWH Hybrid Centralized & Distributed with Drain Water Heat Recovery

- Total cost reductions
- Total space requirements smaller
- Higher performance and lower life cycle costs

## **Approach: System Integration**







Proposed

### **Alignment and Impact: Project Goals**

#### **Project Goals:**

- 30% cost reduction (product, installation, and user costs)
- WS-HPWH COP > 5
- 25% available hot water increase
- 1,000 times reduction in end-of-life CO<sub>2</sub> emissions reduction compared to Refrigerant-134a

Support rapid decarbonization of the U.S. building stock in line with economyide net-zero emissions by 2050 while centering equity and benefits to communities

#### Increase building energy efficiency

Reduce onste energy use intensity in buildings 30% by 2035 and 45% by 2050, compared to 2005

#### Accelerate building electrification

Reduce onsite fossil -based CO<sub>2</sub> emissions in buildings 25% by 2035 and 75% by 2050, compared to 2005

#### Transform the grid edge at buildings

Increase building demand flexibility potential 3X by 2050, compared to 2020, to enable a net-zero grid, reduce grid edge infrastructure costs, and improve resilience.

#### Prioritize equity, affordability, and resilience



Ensure that 40% of the benefits of federal building decarbonization investments flow to disadvantaged communities



Reduce the cost of decarbonizing key building segments 50% by 2035 while also reducing consumer energy burdens



DOE BTO Goals

Increase the ability of communities to withstand stress from climate change, extreme weather, and grid disruptions

Greenhouse gas emissions reductions

50-52% reduction by 2030 vs. 2005 levels Net-zero emissions economy by 2050

## **Alignment and Impact: Energy Justice**



**Energy justice** 40% of benefits from federal climate and clean energy investments flow to disadvantaged communities

#### Equity

- Family sets small ERWH to desired temperature
- Reduction of energy burden on disadvantaged households in cold climates
- All residences are guaranteed hot water
  - 10%+ redundancy addition to centralized systems



Adapted Graphic (Interaction Institute for Social Change | Artist: Angus Maguire)

### **Background: National Market AS-HPWH water heating**



The combined high installation cost and first price of heat pump water heaters (HPWH) is the major reason the market share of HPWHs is only ~1% in the US \*Geoff Wicket

\*Geoff Wickes \*\* Andy Meyer

### **Background:** Multifamily Household Characteristics

Multifamily households: 18% of US households live in 5+ unit multifamily housing.

 Low-income population: Over 43% of households in multifamily buildings belong to low-income group, compared with 30% across all housing types.

### Energy burden:

- The median energy burden of low-income multifamily households is 5.4%, which is 2.3 times higher than that of other multifamily households.
- 25% of low-income multifamily households are severely burdened, spending more than 10% of their income on energy costs.

Source: 2019 American Housing Survey A Drehobl L Ross and R Avala

A. Drehobl, L. Ross, and R. Ayala, "How high are household energy burdens?," Washington, DC, 2006.



#### Source: 2015 Residential Energy Consumption Survey (RECS)

## **Background:** Multifamily Market (cont.)



This offers incentives to the building owners to adopt a centralized scheme with HPWHs, as the payback of HPWH is much shorter (~3-4 years) than its life.

Source: 2019 American Housing Survey; 2015 Residential Energy Consumption Survey; EnergyStar.gov

## **Approach: HPWH improvements**

The project team will realize following improvements in HPWH deployments

- Costs
  - Systems approach taken to analyze initial, installed and life cycle costs
- Footprint
  - Centralized allows for few square feet of water storage
  - Inexpensive low GWP refrigerants can be used in a properly configured utility room
- Efficiency
  - WS-HPWH will have higher COP than AS-HPWH
    - heat source is warmer
    - less resistance to heat transfer in evaporator (liquid/liquid) instead of (liquid/air)
  - Splitting the evaporator away from the tank reduces heat leaks from the tank to the evaporator in unitary systems
  - SWHR allows for upgrading of waste heat lost in the drain to hot water temperatures
    - Better than preheating water when a moderate storage tank is used to collect more energy
  - Utility room installation allows for tight control of heat source

## **Approach: Plumbing Cost**

**Comparing Design Predictions to Actual Peak Flow Rates** Peak Hot Water Flow Rates in Multifamily Buildings 100 UPC Appendix A Design ⊕ UPC Appendix M Design 90 Peak Flow Rate Observed (99th Percentile) Œ Ð Per Minute 80  $\oplus$  $\oplus$ 50 ⊕ Gallons  $\oplus$ Ð Ð Ð 20  $\oplus$ 10 0 \*Sanfroncisco. CA. (24 units). A Nascalero, CA (12 units) - D Oakland, CA CA units), F New Harlord, NY OS united. C "Sanfrancisco, CALLS units), I \*Sanfrancisco. CA (20 units) - N Angeologo, CA (Dunis), C Davis, CA Quinter F Seattle WA (Quinter 1 \* Clovestile, NY (AD Mile), Y Davis. CA Build . A Abany. A Con with C \*Oatland. CA. (B units) to Potestan, N. Chuitar. Sente, WA Cashinita)

"The rules for sizing hot and cold-water distribution piping in buildings were published in the early 1940s and became part of the plumbing code" Hot water systems are oversized for today's fixtures!

			Water Deman	d Calculator (V	VDC v2.0)					
PROJECT NAME : Click for Drop-down Menu →		Single-Family Reside	ľ		Sunday, May 30, 2021 6:42 AM					
FOCTURE GROUPS		FOCTURE	ENTER TOTAL NUMBER OF FORTURES	PROBABILITY OF USE (N)	ENTER FOCTURE FLOW RATE (GPM)	MAXIMUM RECOMMENDED FECTURE FLOW RATE (GPM)	COMPUTED RESULTS FOR PEAK PERIOD CONDITIONS			
Bathroom Fatures	1	Bathtub (no Shower)	0	1.00	5.5	5.5				
	2	Bidet	0	1.00	2.0	2.0	Total No. of Fixtures in Calculation			
	- 3	Combination Bath/Shower	0	5.50	5.5	5.5				
	- 4	Faucet, Lavatory	0	2.00	1.5	1.5				
	5	Shower, per head (no Bathtub)	0	4.50	2.0	2.0	99 <sup>th</sup> Percentile Demand Flow			
	6	Water Closet, 1.28 GPF Gravity Tank	0	1.00	3.0	3.0				
Kitchen Fatures	7	Dishwasher	0	0.50	1.3	13				
	8	Faucet, Kitchen Sink	0	2.00	2.2	2.2	Hunter Number			
Laundry Room Fixtures	9	Clothes Washer	0	\$.50	3.5	3.5				
	10	Faucet, Laundry	0	2.00	2.0	2.0				
Bar/Prep Fixtures	11	Faucet, Bar Sink	0	2.00	1.5	15	Stagnation Probability			
Other Flatures	12	Fixture 1	0	0.00	0.0	6.0				
	13	Fixture 2	0	0.00	0.0	6.0				
	14	Fixture 3	0	0.00	0.0	6.0				
DOWNLOAD RESULT WDC GPM LPM LPS RUN CLICK BUTTON										

https://www.iapmo.org/waterdemand-calculator/



Gary Klein and Associates, Inc.

Where water and energy connect

~

~

### **Approach:** Component, system lifecycle and heat exchanger design

• Investigating adapting the Argonne **GREET Model** to evaluate the energy and emissions impact of different Heat Pump Water Heater configurations to an Advanced Building Construction tool.

VEHICLE CYCLE

### The GREET<sup>®</sup> (<u>G</u>reenhouse gases, <u>R</u>egulated <u>E</u>missions, and <u>E</u>nergy use in <u>T</u>ransportation) model

**GREET 2 Series** Freely available at www.greet.es.anl.gov GREET 2 model: Vehicle cycle modeling for Updated and released annually Support DOE R&D programs Stochastic Carbon Calculator for Land Use Change from Biofuels (CCLUB) Simulation Tool vehic GREET 1 model: Fuel-cycle (or well-to-wheels, WTW) modeling of les vehicle/fuel systems WELL TO PUN

**OFFICE OF ENERGY EFFICIENCY & RENEWABLE ENERGY** 

- Review and design methods to reclaim energy for preheating from wastewater using low-fouling heat exchanger devices.
- RSMeans Guides 2022, an industry standard, are being utilized to determine a "first cut" Heat Pump Water Heater component and installation costs.



#### Year 1: Modeling

- G/NG: At least 1 system identified with 30% cost savings
- Technical risks: high item costs due to supply chain issues
  - Mitigation: estimate costs at high product volume

### Year 2: Scaled experimentation

- G/NG: At least 1 system experimental performance projects 30% cost savings
- Technical risks: expensive heat exchangers
  - Mitigation: analyze lower cost, lower performance heat exchangers

### Year 3: Field deployment pilot

- Technical risks: low space availability for technology
  - Mitigation: consider compact heat exchangers or partial supply heat from air

### **Progress: Systems to be Analyzed in Detail**



### **Progress:** Initial analysis (Retrofit of centralized systems)



Major assumptions lead to conservative initial analysis

1) same COP across technologies  $\rightarrow$  conservative up to 250%

- 2) replacing BTU for BTU between systems  $\rightarrow$  conservative up to 300%
- 3) larger HPWH 75% cost per BTU than smaller unitary  $\rightarrow$  component cost driven

# Thank you

Oak Ridge National Lab Kashif Nawaz (Senior R&D Staff) (865) 241-0972, nawazk@ornl.gov Joseph Rendall, (Associate R&D Staff) (865) 341-0422, rendalljd@ornl.gov



**ORNL's Building Technologies Research and Integration Center (BTRIC)** has supported DOE BTO since 1993. BTRIC is comprised of 60,000+ ft<sup>2</sup> of lab facilities conducting RD&D to support the DOE mission to equitably transition America to a carbon pollution-free electricity sector by 2035 and carbon free economy by 2050.

#### **Scientific and Economic Results**

236 publications in FY22
125 industry partners
54 university partners
13 R&D 100 awards
52 active CRADAs

BTRIC is a DOE-Designated National User Facility

### **REFERENCE SLIDES**

### **Project Execution**

	2023				20	24		2025						
Planned Budget		\$800K					\$800K				\$800K			
Spent Budget		\$40K												
Milestone Descriptions	M1-3	3 1	M4-6	M7-9	M10-12	M1-3	M4-6	M7-9	M10-12	M1-3	M4-6	M7-9	M10-12	
Year 1														
Milestone 1: All components modeled			MS1											
Milestone 2: All systems modeled					MS2									
Milestone 3: Models interact in co-simulation environment				MS3										
Milestone 4: All costs (capital, installed, user) identified in Re-Review					MS4									
Milestone 5: Selection of multifamily configuration with technologies						MS5								
Year 2														
Milestone 1: Components identified and ordered						MS6	5							
Milestone 2: Test bench commissioned								MS7						
Milestone 3: Manuscripts prepared on test bench and results of system test									Μ	S8				
Milestone 4: System tested										MS9				
Milestone 5: Selection of multifamily configuration with technologies										MS1	.0			
Year 3														
Milestone 1: Pilot facilities identified and onboarded											MS11			
Milestone 2: System installed and commissioned in facility											MS1	12		
Milestone 3: Data compiled and reduced for 6 months of operation													MS13	
Milestone 4: Performance of system calculated													MS14	
Milestone 5: Final report manuscript prepared													MS1	

#### Go/no-go decision points (MS5 and MS10)

### Team



Principal Investigator

Kashif Nawaz



Jian Sun

Yangfei Li Ahmed Elatar

Modeling and controls



Mini Malhotra Keju An System cost analysis & Equity champions



Joe Rendall Jamieson Brechtl System design and experimentation



Tim Rooney



**OAK RIDGE** National Laboratory

Jiamin Yin





System design Component cost analysis Heat recovery





Finnian Casey

Undergraduate Laboratory Intern

Steve Memory