

CATEGORICAL EXCLUSION DETERMINATION



Proposed Action Title: Curecanti-Morrow Point No. 2 13.8-kV Distribution Line Fiber Optic Cable Replacement, Structure Replacement, and Guy Wires Installation

Location: Montrose County, Colorado

Project Number: 2023-027

Expiration Date: December 31, 2029

A. PROPOSED ACTION DESCRIPTION:

Western Area Power Administration (WAPA), Rocky Mountain Region (RMR), proposes to replace the existing all-dielectric self-supporting (ADSS) fiber optic cable on its Curecanti-Morrow Point No. 2 (CCI-MP-2) 13.8-kV Distribution Line in Montrose County, Colorado. The existing ADSS cable has multiple broken fibers and is at high risk of failure. The ADSS will be installed between the existing splice points at the Bureau of Reclamation's Morrow Point Power Plant (MP) and WAPA's Curecanti Substation (CCI). The proposed action also involves the replacement of Structure 0-16 on the CCI-MP-2 13.8-kV Distribution Line and the installation of guy wires on an existing structure (unnumbered) adjacent to Structure 0-2 on WAPA's Curecanti-Morrow Point No. 1 230-kV Transmission Line. Equipment used for the proposed action may include UTVs, bucket trucks, wire pullers and tensioners, cranes, splicing trailers, cable reel trailers, and utility trucks. Work will be confined to WAPA's ROW on private lands, and public lands managed by the Bureau of Land Management (BLM). The ROW will be accessed by existing access routes; no access road maintenance or new road construction is authorized.

B. STIPULATIONS PERTAINING TO PROPOSAL:

- 1) If the scope of work of this project changes, RMR's Environment Department must be contacted to determine whether additional environmental review is required.
- 2) **This Categorical Exclusion expires on December 31, 2029.** If all project work has not been completed by the expiration date, or if the need for an environmental compliance extension is anticipated, RMR's Environment Department must be contacted for an updated environmental review.
- 3) **Gunnison sage-grouse critical habitat exists between CCI-MP-2 Structures 0/1 to 0/6. Within these structure ranges, the following conservation measures are required to avoid or minimize the possible effects to both Gunnison sage-grouse and its critical habitat:**
 - a. Only conduct work outside of the GUSG lekking, nesting, and brood rearing season of March 1 to July 15;
 - b. Use existing access routes and remain on them, except when necessary to conduct the described work activities; and

- c. Avoid or minimize disturbance to sagebrush and other shrubs.
- 4) Any injured or orphaned birds and all observed active nests must be immediately reported to RMR Environment at (970) 593-8803 or (970) 342-6462. Any dead birds must be reported to RMR Environment twenty-four (24) hours of discovery. Additional documentation, such as photographs and GPS coordinates, may be requested to support RMR's reporting requirements to the U.S. Fish and Wildlife Service.
 - 5) If any cultural resources are inadvertently discovered during implementation of the proposed action, work within 100 feet of the discovery area must halt immediately and an RMR Archaeologist must be contacted immediately at (970) 302-4753, (970) 286-3523, or (970) 658-6794. Work in the area of discovery must not resume until written notification to proceed is provided by an RMR Archaeologist.
 - 6) If any possible human remains are inadvertently discovered during implementation of the proposed action, work within 100 feet of the discovery area must halt immediately and an RMR Archaeologist must be notified immediately at (970) 302-4753, (970) 286-3523, or (970) 658-6794 (no later than 24 hours from the time of discovery). A reasonable effort must be made to protect the remains from looting and/or further damage. Work in the area of discovery must not resume until written notification to proceed is provided by an RMR Archaeologist.
 - 7) Vehicles and equipment (trailers, trucks, UTVs, etc.) will not be moved between work areas without first taking reasonable measures to ensure they are free of soil, seeds, vegetation matter, or other debris that could contain noxious weed seeds.
 - 8) Activities involving the use of fuel, oil, hydraulic fluid, or other petroleum products must comply with RMR's Spill Response Plan (SRP).

C. NUMBER AND TITLE OF THE CATEGORICAL EXCLUSION BEING APPLIED:
(See text in 10 CFR 1021, Subpart D.)

B4.7. Fiber optic cable

D. REGULATORY REQUIREMENTS 10 CFR 1021.410 (b): (See full text in regulation)

The proposed action fits within a class of actions that is listed in Appendix A or B of 10 CFR 1021.

To fit within the classes of actions listed in Appendix B, a proposal must be one that would not:

- (1) threaten a violation of applicable statutory, regulatory, or permit requirements for environment, safety, and health, or similar requirements of the Department of Energy (DOE) or Executive Orders;
- (2) require siting and construction or major expansion of waste storage, disposal, recovery, or treatment facilities (including incinerators), but the proposal may include categorically excluded



waste storage, disposal, recovery, or treatment actions or facilities; (3) disturb hazardous substances; pollutants; contaminants; or Comprehensive Environmental Response, Compensation, and Liability Act (CERCLA)-excluded petroleum and natural gas products that preexist in the environment such that there would be uncontrolled or unpermitted releases; (4) have the potential to cause significant impacts on environmentally sensitive resources, including, but not limited to, those listed in paragraph B(4) of 10 CFR 1021, Subpart D, Appendix B; (5) involve genetically engineered organisms, synthetic biology, governmentally designated noxious weeds, or invasive species, unless the proposed activity would be contained or confined in a manner designed and operated to prevent unauthorized release into the environment and conducted in accordance with applicable requirements, such as those of the Department of Agriculture, the Environmental Protection Agency, and the National Institutes of Health.

There are no extraordinary circumstances related to the proposal that may affect the significance of the environmental effects of the proposal.

The proposal has not been improperly segmented, and the proposal is not connected to other actions with potentially significant impacts, is not related to other proposed actions with cumulatively significant impacts, and is not precluded by 40 CFR 1506.1 or 10 CFR 1021.211.

E. DETERMINATION:

Based on my review of information conveyed to me and in my possession (or attached) concerning the proposed action, as NEPA Compliance Officer (as authorized under DOE Order 451.1B), I have determined that the proposed action fits within the specified class(es) of action, the other regulatory requirements set forth above are met, and the proposed action is hereby categorically excluded from further NEPA review.

Signature and Date

James Wood, Regional Environmental Manager
Rocky Mountain Region
Western Area Power Administration

Prepared by:
Gail Martinez, Natural Resource Specialist
Brian Joseph, Regional Preservation Official

