



Bipolar Nickel Metal Hydride Battery Development and Testing

**DOE ENERGY STORAGE SYSTEMS
RESEARCH PROGRAM**

ANNUAL PEER REVIEW

November 2 – 3, 2006, Washington, D.C.

James Landi jlandi@electroenergyinc.com

203-797-2699

Program Objectives and Benefits

- The objective of this program is to further develop the bipolar NiMH battery design to be used in high-energy and high-power energy storage applications.
 - Build and demonstrate large-format batteries
 - Demonstrate these batteries in present and future applications
- The bipolar NiMH battery could provide the following benefits:
 - Improve efficiencies by reducing transmission peaking losses and shifting peak demands.
 - Reduce power and voltage sag to users.
 - Provide an efficient method to distribute backup energy/power for utilities to ensure uninterruptible service to their customers.
 - Increase reliability of solar and wind systems that require energy storage.

Program History

- This program commenced September 2005, and is a continuation of previous development and demonstration programs.
- Previous Accomplishments
 - Built and delivered a 600 V, 35 kWh, 20 kW Inverter battery system
 - Effort was in collaboration with First Energy
 - Testing done by EPRI Solutions in Knoxville, TN
 - Built a 500 V, 100 kVA UPS battery system, replacing ultra-capacitors
 - Built and delivered a 48 V, 50 Ah battery for a 3 kW UPS system
 - Successfully demonstrated a high power 40 kW, 350 V battery module
- Present Program Milestones
 - Market Assessment
 - Design and Performance Improvements
 - System Builds and Demonstrations

EEI's Bipolar Wafer Cell Battery Design



- Current flows perpendicular to all electrode surfaces
- Active materials are efficiently utilized, minimizing internal resistance
- Flexible form factor
- 25% higher power
- 25% less volume
- 25% lower manufacturing cost
- Environmentally friendly
- Excellent life

Two Bipolar NiMH Battery Types

High Energy NiMH

- Thicker/higher capacity electrodes
 - High Energy/Lower power per unit weight and volume
 - >50 Wh/kg, >140 Wh/L
 - 35 W/kg, 100 W/L – Continuous
- 12 V to >600 V systems

High Power Applications

- Thinner/lower capacity electrodes
- High power/Lower energy per unit weight and volume
 - >1 kW/kg, >2.6 kW/L - <10 second pulse
 - >30 Wh/kg, >80 Wh/L
- 12 V to >700 V systems

Electro Energy's Market Assessment of High Power and High Energy Storage

- EEl is conducting an ongoing market assessment to identify opportunities and pilot demonstrations for the bipolar batteries
- Three market segments identified as prime candidates for bipolar battery applications
 - Electric Utilities
 - Critical Infrastructure Service Providers
 - Multi-Tenant Buildings
- Energy storage solutions have two significant hurdles to overcome:
 - Education: Understanding the benefits associated with batteries
 - Investment: The economics of battery technology remains a barrier

Design Improvements


- Optimized negative-to-positive ratio resulting in improved performance and increased cycle life.
- Improved electrode production processes
 - Established a continuous nickel foam based production process for energy cells
 - Developed in-house capability to produce hydride electrodes for energy cells
 - Developed a thin coating process for nickel and hydride electrodes for power cells
- Implemented an automatic electrolyte filling process
- Developed and implemented a sealed stack formation process
- Investigated alternate materials leading to cost reductions

Cell Balancing System

- EEI has been utilizing a commercial cell balancing system to balance every 5, 10, 15, 20, or 30 cells in battery systems
- Results in improved capacity, reduced heat, and increased efficiency


Severely Unbalanced Pack Shows 100% Capacity Increase

EEI 40 Cell Module Testing (Capacities With and Without Balancing System)



Typical Pack Shows Greater than 5% Capacity Increase

EEI 20 Cell Module (Capacities With and Without Balancing System)




EEI 4 kW Inverter Peak Shaving/Back-Up System



- 4 kW Inverter
- 1.5 kW Generator
- 3 – 1 kWh Batteries (Each 48 V, 20 Ah)

EEI 4 kW Inverter Peak Shaving/Back-Up System


EEI 4 kW Inverter - Peak Shaving and Back-Up Operation



— Grid Power — Generator Power — Inverter Output Power — Battery Power

EEl 4 kW Inverter Battery Performance

EEl 4 kW Inverter System - Battery Performance




3 kW UPS System



- 3 kW UPS System
- 1 kWh Battery (48 V, 20 Ah)

3 kW UPS System – Battery Data

3 kW Inverter System Battery Performance
Charge and 5 Minute 1500 W Loads



100 kVA/ 500 V High Power UPS System



Module Design

- Five 39-Cell Stacks in Series
- 5 Ah, 250 V
- 6.62" x 15" x 11.5", 100 lbs

Complete System:


- 2 Parallel Strings of 2 Modules Series
- 5 kWh, 100 kVA
- 10 Ah, 500 V

Actual Testing System

- 1 Strings of 2 Modules in Series
- 2.5 kWh, 50 kVA
- 5 Ah, 500 V

100 kVA UPS Battery 1-Day Test Profile (50% Load) Cycles 793-804

100kVA UPS Battery System 1-Day Test Profile
12 Cycles (793 - 804)




**Battery System has Maintained Consistent Performance
Through 800 Cycles**



100 kVA UPS Battery Daily Energy In and Out (50% Load), at 800 Cycles

100kVA UPS Total Energy In/Out for Each Day (50% Load)



Plug-In Hybrid Electric Prius With Electro Energy's Bipolar Nickel Metal Hydride Battery



Module Configuration

60 cells, 15 Ah, 73 V, 1.1 kWh

60 lbs



Battery System

Two parallel strings of three modules in series

21.25" x 39.00" x 8.00", <400 lbs


All electric range: 20-22 miles

Plug-In HEV - 19.7 Mile Drive (All-Electric)

PHEV Battery Discharge Profile - Parallel with HEV Battery

PHEV Prius Test Run

07-11-06



21.3Ah, 4.5kWh removed – 0.92Miles/Ah, 4.38Miles/kWh)

Summary and Conclusions

- Bipolar cell design was optimized
- Module and battery performance was improved through cell/stack balancing
- Bipolar cell production processes were developed for volume manufacturing
- High-voltage modules/systems were tested, achieving multiple cycles
- The bipolar NiMH batteries were demonstrated in multiple applications

Continued and Future Efforts

- Manufacturing Process Development
- Bipolar Battery Module Optimization
 - 144 V, 6 Ah High Power Modules
 - 75 V, 20 Ah Energy Modules
 - 110 V, 15 Ah Energy Modules
- Battery Systems Pilot and Demonstration

Company Developments

- April 2006, acquired assets of battery facility in Gainesville, Florida area formerly owned by Energizer
 - Leased 200,000 Ft² of manufacturing space
 - Simultaneous with acquisition raised working capital to be used for:
 - Equipment up-grades
 - New Equipment
- Gainesville acquisition will accelerate commercialization and growth plans:
 - High volume electrode manufacturing for Li-Ion and Ni based products
 - Highly automated capabilities for 18650 Li-Ion cells – 30m/yr
 - Equipment can be adapted for bipolar battery manufacturing
 - High volume commercialization of bipolar Ni-MH batteries
 - Leverage bipolar expertise developed for Ni-MH into Lithium-Ion batteries
- Gainesville facility provides EEI with necessary manufacturing assets to become a leading supplier of specialty rechargeable batteries in North America



Acknowledgements

Electro Energy, Inc. has received funding for this effort from the
Department of Energy.

In particular EEI would like to thank Dr. Imre Gyuk
of The Department of Energy

Nancy Clark and David Ingersoll of
Sandia National Laboratories for Program Management