

Evaluation of Lead-Carbon Storage Devices for Utility Applications

Enders Dickinson

Specialty Chemicals Division

MeadWestvaco Corporation

(843)746-8331

ed16@meadwestvaco.com

September 27, 2007

Peer Review

Electrical Energy Storage

Applications and Technologies

San Francisco, CA

Program Participants

MeadWestvaco

Charleston, SC
Enders Dickinson
Spencer Everitt
Mark Creech
Carbon Development
Lab and Battery Testing



Sandia National Laboratories

Albuquerque, NM
Nancy Clark
Tom Hund
Jim Van Den Avyle
Battery Testing and Verification
Analytical Support



Springfield, MO

Frank Fleming
Bob Shirk
Michelle Cantrell
Manufacturing and Battery Testing
Battery Expertise



Washington, DC

Imre Gyuk
Program Sponsor



battery energy
power solutions for tomorrow's world

Fairfield, Australia

Dave Brown
Gel Battery Manufacturing



Genoa, OH

Joe Badger
Battery Testing (Std. Apps.)



A Division of HAMMOND GROUP, INC.

Hammond, IN

Matthew Spence
David Boden
Expander Development

Electric Transportation

Applications

Phoenix, AZ

Don Karner
Russell Newnham
Battery Testing (Utility/Cycling)

Phase One: *Explore possible advantages to carbon in energy storage*


- Evaluate lead based energy storage technologies
- Develop carbon for lead based technologies
 - Increase cycle life for some applications
 - Improve charging characteristics
 - Verify claims made on energy storage devices

Phase Two: *Investigate performance benefit and refine understanding*

- Focus on mechanisms that result in performance benefit
- Verify Performance

Phase Three: *Determine best technology for application needs*

- Select best technology for 1MW utility demonstration



- ◆ Carbon increases life under shallow PSOC conditions
- ◆ Carbon increases charge acceptance during overcharge

Questions from Phase One:

1. Are impurities interfering with performance trends?
2. Is carbon loading too high?
3. Did we evaluate the correct battery technology?
4. Can the carbon properties be optimized?

Responses included in Phase Two:

1. Acid wash activated carbon, use ultra pure carbon black
2. Lower target carbon loadings to 3% or less
3. Test carbon performance in gel electrolyte batteries vs. AGM
4. Functionalize carbons to explore optimization opportunities

Battery Builds:

NorthStar	12/06	23 Types ~6 replicates	40 AH
Hammond	4/07	23 Types ~3 replicates	~1 AH
Battery Energy	4/07	6 Types ~14x2 replicates	4 AH




Phase Two: NorthStar AGM Batteries

Run	BaSO4	CB	AC	AC-Type	Graphite	Vanisperse	Indulin	Comments
1	STD	0.25%	1.2%	A	-	0.18%	-	Reduce H2
2	STD	0.25%	1.2%	A	-	0.37%	-	Reduce H2
3	STD	0.25%	1.2%	B	-	0.18%	-	lignin solubility
4	STD	0.25%	1.2%	C	-	-	-	lignin solubility
5	STD	0.25%	1.2%	B	-	0.18%	0.18%	lignin solubility
6	STD	0.25%	1.2%	C	-	-	0.37%	lignin solubility
7	STD	0.25%	1.2%	D	-	0.18%	-	Carbon Baseline
8	STD	0.25%	1.2%	D	-	0.37%	-	Carbon Baseline
9	STD	0.25%	3.7%	A	-	0.18%	-	Reduce H2
10	STD	0.25%	3.7%	A	-	0.37%	-	Reduce H2
11	STD	0.25%	3.7%	B	-	0.18%	-	lignin solubility
12	STD	0.25%	3.7%	C	-	-	-	lignin solubility
13	STD	0.25%	3.7%	B	-	0.18%	0.18%	lignin solubility
14	STD	0.25%	3.7%	C	-	0.00%	0.37%	lignin solubility
15	STD	0.25%	3.7%	D	-	0.18%	-	Carbon Baseline
16	STD	0.25%	3.7%	D	-	0.37%	-	Carbon Baseline
17	STD	0.25%	1.2%	E	-	0.37%	-	H2 and O2
18	STD	0.25%	3.7%	E	-	0.37%	-	H2 and O2
19	STD	0.25%	-	-	-	0.18%	-	baseline
20	STD	0.25%	-	-	-	0.37%	-	baseline
21	3X STD	0.25%	-	-	-	0.37%	-	Grain Size
22	STD	2.44%	-	-	2.44%	0.37%	-	Modified ALABC
23	STD	0.25%	-	-	-	0.18%	-	40FT



- Industrial→FT
- Mixing Calcs
- Lignin Omission
- Low Capacities

- ✓ Capacity
- ✓ Self-Discharge
- ✓ Float
- ✓ Gassing
- ✓ Charge Acceptance
- ✓ Recharge Efficiency
- ✓ PSOC Cycle Testing



Phase Two: NorthStar AGM Batteries



- ◆ Comparable End-of-Line capacities
- ◆ Retest shows significant capacity drop
- ◆ Normalized data = increased NAM utilization





- ◆ No significant stand losses observed
- ◆ Final OCV comparable to standard and typical performance



-18°C Chamber
Discharge 400A

C: 16 A, 14.7 V, 10 hrs.
Rest 2 hrs.
D: C/1
C: 2.27 vpc to 105%

- ◆ Carbon batteries show reduced CCA: not ideal for high rate, low temperature
- ◆ Recharge Time (Current Acceptance): initial capacity issues, ideal charge?



Float
2.27 vpc
2.35 vpc
2.45 vpc

Float @ 2.27 vpc
Stabilize current
Measure rate
(Water displacement)

- ◆ Float/Gassing data: variable time snap-shot; variable electrolyte saturation
- ◆ Recombination variability and matrix design = no apparent data trends

Simple PSOC

50% initial SOC [D: 26 A, **30 min**]
2C (1 min charge/discharge) [~3% SOC]
10 s rests between pulses
C test & restart cycle if EODV = **11 V**

$T_{\text{rest}} = 41^{\circ}\text{C}$; wait for **35°C**
Recharge = 6 A, 2.45 vpc, 12 hrs
Maximum TOCV = **16.5 V**

Modified Simple PSOC



50% initial SOC [D: 26 A, **11.9 V**]
2C (1 min charge/discharge) [~3% SOC]
10 s rests between pulses
C test & start subcycle at EODV = **11.5 V**

Sub-cycle

2C (1 min charge/58 s discharge) [115x]

$T_{\text{rest}} = 50^{\circ}\text{C}$; wait for **49.5°C**
Recharge = 6 A, 2.45 vpc, 12 hrs
Maximum TOCV = **17.5 V**
Maximum cycle time = **2 weeks**

- ◆ Battery design changed T behavior: T rests = polarization masking differences
- ◆ Initial capacity variation addressed via initial discharge to voltage (not time)
- ◆ SOC adjustment (“Sub-cycle”) of 15% recharge @ ~40% SOC





- ◆ Capacity drop typically proportional to bulk sulfate formation
- ◆ Power pulse availability demonstrated by low polarization during cycling
- ◆ Improved performance for battery types 22, 3, 7, 6, (5) (of lower loadings)
- ◆ Monitor remaining AGMs, but recognize high energy/low power limitations

Group #	Loading	Carbon Type
21	0%	STD
1	1%	
2	2%	Type A X070200
3	5%	
5	1%	
6	2%	Type A X070198
7	5%	
8	1%	
9	2%	APH 2939
10	5%	
11	1%	
12	2%	Type B X070702
13	5%	
14	1%	
15	2%	Type B X070701
16	5%	
17	2%	2-2
18	1%	
19	2%	Type A1 X070202
20	5%	
22	1%	
23	2%	ABG1010
24	5%	
25	6%	Type A1 X070202 - 5% ABG1010 - 1%


Research Cells

- 3-Plate (2P:1N)
- Type/Loading
- Simple PSOC





- ◆ Carbon addition shows some degree of increased utilization



- ◆ Two sets of cycling completed – variation in test cells (compression?)
- ◆ ABG, A-198, A1-202, (APH) showing improved average screening cycle life

Battery Description	Carbon	Type
MWV-STD	0.25	CB
BE-STD	1%	CB
MWV-A	1%	MWV
MWV-B	2%	MWV
MWV-C	3%	MWV
MWV-D	1%	Graphite

Gel VRLA Batteries (Silica/Acid Electrolyte)

- ✓ Increased Cycle Life
 - ✓ Improved Charge Efficiency
 - ✓ Improved Heat Dissipation
 - ✓ No Acid Stratification
- Ideal for Wide PSOC Cycling*


- Five units at JBI 7/23 [Characterization]
- Remaining units at MWV 9/1 (Sandia, ETA)
- ETA Testing to begin In October [Cycling]

Cycling Options

PSOC: Advanced PSOC

Utility: Koontz / "Karner" / New Cycle





- ◆ Matrix shows promise for conclusive results

System Design and Cost Estimates

Electric Transportation Applications

Don Karner


Electric Transportation Applications

(602)356-2783

dkarner@etecevs.com

- Task 1 - Overall system design
- Task 2 - Power inverter design/cost
- Task 3 - BMS design/cost
- Task 4 - Overall system cost

Task 1: System Design



Sizing Assumptions

Reserve Strings	10%	(0 = no reserve)	
End of Life Derate	80%	(100 = no derate)	
Module Manufacturer	Northstar	Sonnenschein	Battery Energy
Module Model	170FT	8OPzV800WE	2SG875
Module Voltage	12	2	2
Module Cost	\$220.00	\$450.00	\$350.00
Module Capacity (Ah @ C/10)	170	800	875



Task 1: Battery Cost

PSoC Window [%]	Discharge Rate [C]	Cycle Life			Single String - Energy (to 1.8 vpc)		
		Northstar [N]	Sonnenschein [N]	Battery Energy [N]	Northstar (kWh)	Sonnenschein (kWh)	Battery Energy (kWh)
10	C/10	10,000	15,000	16,000	102.29	432.0	333.0
20	C/5.0	8,000	12,000	14,000	85.21	372.6	267.0
30	3/3.3	6,000	10,000	12,000	81.61	324.0	240.0
40	C/2.5	5,000	8,000	10,000	78.75	302.4	214.2
50	C/2.0	3,000	5,000	7,500	76.34	274.3	198.6
60	C/1.7	1,000	3,000	5,000	74.21	266.2	182.4

PSoC Window [%]	Parallel Strings			Modules		
	Northstar (N)	Sonnenschein (N)	Battery Energy (N)	Northstar (N)	Sonnenschein (N)	Battery Energy (N)
10	117	28	45	5850	8400	13500
20	70	16	28	3500	4800	8400
30	49	12	21	2450	3600	6300
40	38	10	17	1900	3000	5100
50	31	9	15	1550	2700	4500
60	27	7	14	1350	2100	4200

PSoC Window [%]	Battery Cost			Battery Cost/Cycle		
	Northstar (\$)	Sonnenschein (\$)	Battery Energy (\$)	Northstar (\$)	Sonnenschein (\$)	Battery Energy (\$)
10	\$ 1,287,000	\$ 3,780,000	\$ 4,725,000	\$ 129	\$ 252	\$ 295
20	\$ 770,000	\$ 2,160,000	\$ 2,940,000	\$ 96	\$ 180	\$ 210
30	\$ 539,000	\$ 1,620,000	\$ 2,205,000	\$ 90	\$ 162	\$ 184
40	\$ 418,000	\$ 1,350,000	\$ 1,785,000	\$ 84	\$ 169	\$ 179
50	\$ 341,000	\$ 1,215,000	\$ 1,575,000	\$ 114	\$ 243	\$ 210
60	\$ 297,000	\$ 945,000	\$ 1,470,000	\$ 297	\$ 315	\$ 294

Task 2: Inverter Design



Non-recurring cost

Engineering	\$ 218,800
Contingency	\$ 43,760

Recurring cost

Production	\$ 132,272
Contingency	\$ 13,227

- Battery cycling to confirm battery sizing needs
- BMS conceptual design complete
- Overall system requirements defined
- Preliminary cost analysis underway

- Inverter cost an order of magnitude less than battery cost
- Regulator power/energy ratio requires optimization
- Battery cycle life and capacity requires validation

