



# Large Format Carbon Enhanced VRLA Battery Test Results

## EESAT 2009

Funded by the Energy Storage Systems Program of the  
U.S. Department Of Energy (DOE/ESS) through Sandia  
National Laboratories (SNL)

October 4 - 7, 2009  
Seattle, Washington

*Presented by:*  
**Tom Hund**

Sandia National Laboratories  
Albuquerque, NM  
(505) 844-8627  
tdhund@sandia.gov

\*Sandia is a multi-program laboratory operated by Sandia Corporation, a Lockheed Martin Company,  
for the United States Department of Energy's National Nuclear Security Administration under Contract DE-AC04-94AL85000.



## Objective

- ◆ **Test Advanced Lead-Acid Battery Consortium (ALABC) technology for utility partial state of charge (PSOC) cycling applications. Utility applications may include:**
  - ❖ **Wind farm energy smoothing**
  - ❖ **Photovoltaic energy smoothing**
  - ❖ **Utility ancillary services**

# Energy Storage System

- ◆ **East Penn Manufacturing**

- ❖ Large format ALABC carbon enhanced absorbed glass mat (AGM) valve regulated lead-acid (VRLA) for utility PSOC cycling applications






# Test Plan For Battery

- ◆ **Capacity.**
- ◆ **DC Ohmic resistance**
- ◆ **Float current**
- ◆ **Utility PSOC cycle test (10% DOD @ 50% SOC)**
- ◆ **Final DC Ohmic resistance**
- ◆ **Final capacity**


# Capacity Curve For Unigy II and Carbon Enhanced Battery



# Alber Cell Impedance After Indicated Cycles


All Measurements at 100% SOC  
Sum For All Cells = 2.2 to 2.7 milli-Ohms

- 0 Cycles
- 5,547 Cycles
- 7,734 Cycles
- 8,529 Cycles




# Ohmic Discharge Voltage Drop After Cycling


## 200 Amp Discharge After 8,529 Cycles 100% SOC



## Battery Discharge Voltage Drop 100% SOC




# Float Current




- Cell 1 (V)   Cell 2 (V)   Cell 3 (V)   Cell 4 (V)   Cell 5 (V)   Cell 6 (V)   Cell 7 (V)
- Cell 8 (V)   Cell 9 (V)   Cell 10 (V)   Cell 11 (V)   Cell 12 (V)   Current(A)




# Utility PSOC cycle test at 200A (10% DOD @ 50% SOC)




# Utility PSOC cycle test at 400 A (10% DOD @ 50% SOC)



# Capacity As A Function of PSOC Cycles



# Initial and Final Capacity At 200A





# Summary

- ◆ **The East Penn ALABC carbon enhanced large format VRLA has proven to cycle well at a partial state of charge.**
  - ❖ Final capacity at 200A after 8,529 PSOC cycles was measured at 851 Ah at 32 C. This is 102% of initial capacity measured at 32 C.
  - ❖ During PSOC cycling the capacity exceeded 120% of initial capacity after 8,529 PSOC cycles.
  - ❖ Capacity increased after 3,400 cycles from a low of 87% of initial capacity to over 120% at 8,529 PSOC cycles
  - ❖ Capacity measured during PSOC cycling was much higher than capacity after an extended rest
- ◆ **Ageing Performance degradation:**
  - ❖ Higher operating temperature (from 9 to 12 C above ambient)
  - ❖ Fewer PSOC cycles (about 1/3 to 2/3 of initial number)
  - ❖ Increased Cell voltage divergence at end of PSOC cycling
- ◆ **Future work will include an energy storage system for photovoltaic grid tied energy smoothing.**